

(MECH. GALV)

HIGH STRENGTH BOLTS ASTM A325 TYPE 3 = AASHTO M164 TYPE 3
HEAVY HEX NUTS ASTM A563-DH3 = AASHTO M291-DH3
HARDENED WASHERS ASTM F436 = AASHTO M293 WEATHERING

HIGH STRENGTH BOLTS ASTM A325 TYPE 1 = AASHTO M164 TYPE 1
HEAVY HEX NUTS ASTM A563-DH = AASHTO M291-DH
HARDENED WASHERS ASTM F436 = AASHTO M293

ALL TYPE 1 BOLTS, NUTS AND WASHERS SHALL BE MECHANICALLY GALVANIZED (ASTM B695 CLASS 50).

TVGA CONSULTANTS

☐ FURNISH AS CORRECTED
☐ REVISE AND RESUBMIT

[REVISIONS AND RESUBMIT]
ENGINEER has reviewed Shop Drawings and Samples and other information which is required to submit, only for conformance with the information given in the Contract Documents and compatibility with the design concept of the completed Project as a functioning whole as indicated in the Contract Documents. Such reviews do not extend to means, methods, techniques, sequences or procedures of construction or to safety precautions and programs inherent thereto. Such reviews are not to be construed as certification or approval. Contractor is responsible for dimensions to be confirmed and correlated at the job site; for information that pertains only to the fabrication processes or to techniques of construction; and for coordination of the work of all trades.

BY: Ashted

PROJECT No: ACIM 091-1(33)
STA. 22+69.92 TO STA. 25+28.
BRIDGE No. 3N (NORTHBOUND)
TOWN OF GUILFORD

FABRICATED BY COLFAX

HOLES _____ SHOP FASTENERS

SHOP PAINT

SHOP INSPECTION

GENERAL NOTES

REVISIONS		
DATE	NO.	BY
	R1	

ORDER NO. 08-18537H22

DETAILS OF FIELD BOLTS

PROJECT I-91 OVER BROAD BROOK AND
BROAD BROOK ROAD

LOCATION WINDHAM COUNTY, VT

CUSTOMER MEC CONSTRUCTION

CAROLINA STEEL GROUP, L

MADE BY GM

MADE BY _____
CHECKED BY **PDC/SB**

SQUAD LEADER Precise Drafting Co, Inc

DATE 09-08

SHEET HF12