

LIGHTING FIXTURE SCHEDULE						
TYPE	MANUFACTURER	STYLE	CAT. NO.	FINISH	DIFFUSER	REMARKS
A	KEYSTONE	NEUTRON	NE-240-S	WHITE	POLY	FLOOR 2-40W RS WW
B	KEYSTONE	SATURN	SA-240	WHITE	POLY	FLOOR 2-40W RS WW
C	MILLER	RM SHAL	AE 3212	WHITE ON ALUM.	—	WALL
D	MSPHILBEN	—	4-314E	ALUM.	GLASS	INCAND 1-150W IF
E	MSPHILBEN	—	68-40	ALUM.	GLASS	INCAND 1-200W IF
F	ART METAL	—	1-1001 WS	WHITE	W/ GLASS	INCAND 1-150W IF
G	MILLER	RM SHAL	AE-3211	WHITE ON ALUM.	—	INCAND 1-150W IF
H	HOLOPHANE	WALL MOUNT	400	ALUM.	GLASS	INCAND 1-150W IF
K	GENERAL ELECTRIC	WALL MOUNT	GE 5751-7	ALUM.	—	INCAND 1-75W IF
X	MILLER	GENERAL ELECTRIC	SB-1201	ALUM.	—	6 LAMPS BY MFG.
L	GENERAL ELECTRIC	PAR 55 DOUBLE	PAR 55 DOUBLE	ALUM.	RED	INCAND 2-200W IF

LEGEND			
SYMBOL	DESIGNATION	MTG. #	CAT. NO.
□	FLUORESCENT LIGHTING FIXTURE - LETTER DESIG. TYPE	SEE SCHEDULE	
⌘	INCANDESCENT LIGHTING FIXTURE - LETTER DESIG. TYPE	SEE SCHEDULE	
⌘	INCAND. LIGHTING FIXTURE - LETTER DESIG. TYPE	SEE SCHEDULE	
⌘	EXIT LIGHT	SEE SCHEDULE	
—	BRANCH CIRCUIT - WIRING CONCEALED IN CEILING	SEE SCHEDULE	
S, S ₁ , S ₂	SWITCH 1 POLE 3 WAY 4 WAY - QUIET TUMBLER	AH 1892	40
SE	OIL BURNER EMERGENCY SWITCH W/ RED PLATE	AH 52625	40
⊗	DUPLEX GROUNDING RECEPTACLE	GE 9226-5	40
⊗	WEATHERPROOF DUPLEX GROUNDING RECEPTACLE	AH 52625	40
⊗	CLOCK RECEPTACLE	AH 52625	40
⊗	JUNCTION BOX	AS NOTED	
⊗	ELECTRIC MOTOR - H P INDICATED	AS NOTED	
⊗	DISCONNECT SWITCH 1P 1HP W/ PROPER HEATER	AS NOTED	
⊗	LOCKING SWITCH 1 POLE (PROVIDE KEY)	AS NOTED	
⊗	TELEPHONE OUTLET	AS NOTED	

LIGHTING PANEL SCHEDULE			
CIR. NO.	BREAKER	EQUIPMENT SERVED	REMARKS
PANEL LPS	CIRCUIT BREAKER TYPE G.E. NLT TO 120/240V 1P 3-W		
1-14	20	1 LIGHTING	
15-27	20	1 RECEPTACLE	
28	30	1 GARBAGE RECEPTACLE	
29	20	1 ELECT. LOCK DOOR # 48	
30-35	20	1 SPACE	
36-42	20	1 SPACE ONLY	
PANEL LHV	CIRCUIT BREAKER TYPE G.E. NLT TO 120/240V 1P 3-W		
1-9	20	1 LIGHTING	
10-17	20	1 RECEPTACLE	
18-20	20	1 SPACES	
21-30	20	1 SPACE ONLY	
PANEL LRAD	CIRCUIT BREAKER TYPE G.E. NLT TO 120/240V 1P 3-W		
1	20	1 LIGHTING - RM 215	
2	20	1 BENCH RECEPTACLE	
3	20	1 LIGHTING & RECEPTABLES, RM 215	
4,5,6	20	1 SPACES	

POWER PANEL SCHEDULE			
CIR. NO.	BREAKER	EQUIPMENT SERVED	REMARKS
PANEL P-1	CIRCUIT BREAKER TYPE G.E. NLT TO 120/240V 1P 3-W		
P-1	20	2 LIGHTING PANEL LPS	
P-2	20	2 LIGHTING PANEL LHV	
P-3	20	2 EMERGENCY LIGHTING PANEL LEL	
P-4	20	1 EXH. FAN # 1	
P-5	20	1 EXH. FAN # 2	
P-6	20	1 EXH. FAN # 3	
P-7	20	1 EXH. FAN # 4	
P-8	20	1 EXH. FAN # 5	
P-9	20	1 EXH. FAN # 6	
P-10	20	1 UNIT HEATER	
P-11	20	1 PAR 55 DOUBLE FLOODS	
P-12	20	1 SPACE	
P-13	20	1 SPACE	
P-14	20	2 SPACE	
P-15	30	2 SPACE	
P-16-20	30	2 SPACE ONLY	

NOTES -
1. ALL ELECTRICAL SERVICE PANELS TO BE MOUNTED ON 3/4" C-D EXT. GRADE PLYWOOD (SEE SPECS.)
2. THE ELECTRICAL CONTRACTOR SHALL RUN ELECTRICAL WIRING TO ALL EXHAUST FANS, AND THE HEATING & VENTILATING CONTRACTOR SHALL MAKE ALL NECESSARY CONNECTIONS FOR PROPER OPERATION OF THESE FANS.

STATE OF VERMONT
DEPARTMENT OF ADMINISTRATION
MONTPELIER, VERMONT

ST. JOHNSBURY OFFICE BUILDING
Electrical Plan & Schedules

DATE: 4/23/72
DRAWN BY: GJM
DESIGNED BY: GJM
APPROVED BY: GJM
CHECKED BY: GJM
DATE: 5/1/72
DWG. NO.: E-1
12 of 12

EMERGENCY LIGHTING PANEL SCHEDULE		
CIR. NO.	BREAKER	EQUIPMENT SERVED
PANEL "EL"	CIRCUIT BREAKER TYPE G.E. NLT TO 120/240V 1P 3-W	
1	20	1 LIGHTING - RM 224
2	20	1 RECEPTACLE - RM 224
3	20	1 LIGHTING - RM 220
4	20	1 RECEPTACLE - RM 220
5	20	1 LIGHTING - RM 220
6	20	1 CORRIDOR LIGHTING & EXT. LIGHT
7	20	1 BOLLER LIGHTING - RM 215
8	20	1 BURNER - RM 223
9	20	1 PUMP - P-1 - ZONE 1
10	20	1 PUMP - P-2 - ZONE 2
11	20	1 PUMP - P-3 - ZONE 3
12	20	1 GAS PUMP
13	20	1 PANEL LRAD
14	20	1 EXIT & VESTIBULE LIGHTS, HIGHWAY
15	20	1 STD. WALL RECEPTABLES, RM 215
16	20	1 LIGHTS & OUTLETS, RM 215-B
17-20	20	1 SPACES

